

SPECIFICATION GUIDELINE FOR ES-SERIES ENCLOSURES

910ES3042

Full Specification

General

91" High X 30" Wide X 42" Deep

The enclosure must be Great Lakes product model #910ES3042

The enclosure must UL listed to UL60950-1 (Standard for Information Technology and Communications Equipment, Cabinet, Enclosure & Rack Systems.) Dimensions shall be 91" High, 30" Wide & 42" Deep. Featuring mesh contour doors, split mesh doors, split fan doors, split solid doors, perimeter vented doors or solid doors, locking lift-off side panels (solid or vented) removable solid, vented or fan top panels. Doors, sides & tops must be 16 Ga. The enclosure shall be constructed of cold rolled steel (CRS) utilizing a fully welded 14 Ga. steel frame design with five bends in the corner post for superior strength. Shall be able to hold 2000 lbs on optional levelers, casters or bolted to the floor. Shall have two pair of universal cage nut mounting rails that must be 19" EIA 310-D compliant. Rails must be infinitely adjustable front to back. Networking of multiple enclosures must be possible through the use of tool-less hardware. Manufacturer shall ship enclosure completely assembled including accessories such as cable management, shelves, & power strips. (Assembly must be per customer's instructions if provided) Manufacturer must be ISO 9001:2000 registered.

Floor Mounting The base unit frame shall have four separate floor mounting locations in the bottom. Threaded studs 5/16 to accommodate set of four (4) plate casters, threaded ½-13 holes to accommodate leveling glides and ¾" floor anchoring holes. Anti-tip option to be fully retractable. (Casters, levelers & anti-tip legs are optional)

Rack Mounting Mounting rails shall be #12 Ga. infinitely adjustable with 48 Rack Mount Units (RMU) markings the complete length of the rail. RMU markings to start at bottom and count up. Universal (M6) rails shall be multi-vendor server compliant. Rails shall be powder-coated and have pass through holes with cable management tie down slots both vertical and horizontal.

Grounding The base unit frame must have four (4) M6 x 12mm copper plated grounding studs located in bottom corners of the enclosure. Right rear bottom of the frame to have a double ½-20 threaded zinc plated stud to allow for mounting of copper ground lug. All doors must include a minimum of two (2) M6 x 12MM copper plated grounding studs located at the top and bottom of the door. All side panels must include one (1) M6 x 12mm copper plated grounding stud located at the bottom of the side panel.

Cable Management The base unit frame must accommodate optional vertical and horizontal cable management lacing bars which are fully adjustable in the enclosure and allow for cable bundles in excess of 5". Rear must accept vertical cable trough. (VCT cable trough series)
All 19" rack mount cable management must be installed at time of shipment.

Cable Access The top panel shall be removable. Top cabinet frame shall have a cable knock-out in the rear that is 7"D x 16" W allowing for 112 square inches for cable access. Additionally six (6) cable access knock-outs shall be on the top of the enclosure. (Two (2) 3.38" x 7" & four (4) 3.38" x 12") Bottom to have four cable access openings. Middle must have a cable access opening (minimum 14.36" x 23.25"). Rear must have a cable access opening (minimum 3.50" x 18.00" 63 sq. in.). This rear access shall have a minimum of four (4) 6" cable hook & loop

straps. Rear corner posts shall have side cable knock-outs to allow for enclosure to enclosure cable pass thru. They will be 3.25" x 37.50" and two (2) per side.

Doors Mesh contour door must have easy latching door handle. All other doors must fit flush with the base and swing open 180°. All doors must have three field reversible hinges using only the hardware provided. Mesh doors shall be at least 64% open measured in useable EIA units. Door shall have lockable handles. Base unit frames must have gasketing for the doors. Doors shall have lockable handles. Base unit frames must have gasketing for the doors. The following doors must be available as options: Solid, split mesh, split fan, split solid or mesh contour.

Side Panels The base unit frame must be able to accommodate locking, quick release, tool-less lift off side panels. Base unit frame must have gasketing for the side panels. The side panels should be flush with the base unit.

Top Panel Top panels shall be removable. Options shall be solid, vented, three-fan low profile assembly and single or dual ten-inch fan assemblies. Panels to accept ladder rack bracket.

Hardware Enclosure shall ship with package of cage nut hardware. (M6 Cage nut & Screws)

Power The base unit frame must have the ability to mount up to three (3) vertical power strips mounted in each rear corner using button mounting. Front corner shall be able to accept one (1) power strip per side.

Quick Spec.

910ES3042

91" High X 30" Wide X 42" Deep

The enclosure must be Great Lakes product model #910ES3042 & be UL listed to UL60950-1 Enclosure frame must be fully welded and be constructed out of cold rolled steel (CRS) utilizing a fully welded 14 Ga. steel frame design with five bends in the corner post for superior strength and be able to hold 2000 lbs on casters. Dimensions shall be 91" High, 30" Wide, 42" Deep.

Doors must fit flush with the base and swing open 180° and be 16 Ga. CRS. All doors must have three (3) field reversible hinges using only the hardware provided. Mesh doors shall be 64% open measured in useable EIA units.

Enclosure shall have two (2) pair of 12 Ga. universal cage nut mounting rails that are 19" EIA 310-E compliant. Rails must be infinitely adjustable and have (48) RMU markings counting from bottom up.

Enclosure frame must allow for optional leveling glides, casters, floor mounting. Enclosure shall have copper plated grounding studs on base unit doors, sides and tops.

Top panels shall be removable.

Enclosure shall have 112 sq. in. top rear cable knock out. Top also to have an additional six (6) cable access knock-outs. (Two (2) 3.38"x 7, four (4) 3.38" x 12") These opening must be able to accept optional brush grommet kit. The bottom shall have cable entry of 287 sq. in.

The base unit frame must be able to accommodate flush, gasketed, locking, quick release, tool-less lift off side panels.

Enclosure must accommodate optional vertical and horizontal cable management lacing bars that are fully adjustable in the enclosure. Rear corner post must be able to accept one (1) or two (2) vertical cable troughs.

All 19" rack mount cable management must be installed at time of shipment.

The base unit frame must have the ability to mount up to three (3) vertical power strips in each rear corner using button mounting.

Networking of multiple enclosures must be able to be done by using tool-less hardware. Manufacturer shall ship enclosure completely assembled including accessories such as cable management, shelves, & power strips. (Assembly must be per customer's instructions if provided) Enclosure shall ship with package of cage nut hardware. Manufacturer must be ISO 9001:2000 registered.