



SPECIFICATION GUIDELINE FOR WS Series Wall Mounts

General

The Wall mount enclosure must be UL listed to UL60950-1 (Standard for Information Technology and Communications Equipment, Cabinet, Enclosure and Rack Systems.)

Mounting rails shall conform to 19" EIA 310-D

Dimensions shall be 24, 36, 48 or 72"H x 24"W x 24"D

Unit must be 3 "piece" sectional design using heavy duty bolt on steel hinged between wall section and middle section. Lockable front solid or plexi door. Pull latch system to open secured middle section. Wall mount to be reversible allowing for right or left hand swing. Top and bottom set up to accept fan assembly and set of 5 casters.

Black durable powder coat finish on 14-gauge steel.

Manufacturer must be ISO 9001:2000 registered.

Mounting -The base unit must have two (2) pair of 19" rack mount rails that tapped 12-24. Adjustable front to rear.

Cable Access -Rear section shall have three (3) knockout in center back and top/bottom for conduit sizes 1, 2, 3 & 4".

Doors -Doors to be plexi-glass or solid. Base unit must have gasketing for the doors.

Sides -Sides of center section to have option for solid or vented sides

Cable Management- all 19" rack mounted cable management to be installed. (Location per customer request)

Power Strips- all 19" rack mounted power strips to be installed on the rear rails.

Fans- Optional fan assembly with two (2) low profile 75 (cubic feet per minute) CFM fans.

